University of Houston Master Specification

<Insert Project Name> <Insert U of H Proj #>

<Insert Issue Name> <Insert Issue Date>

SECTION 26 2718 - MISCELLANEOUS ELECTRICAL CONTROLS AND CONTROL WIRING

Maintain Section format, including the UH master spec designation and version date in bold in the center columns of the header and footer. Complete the header and footer with Project information.

Revise this Section by deleting and inserting text to meet Project-specific requirements.

This Section uses the term "Engineer." Change this term to match that used to identify the design professional as defined in the General and Supplementary Conditions.

Verify that Section titles referenced in this Section are correct for this Project's Specifications; Section titles may have changed.

Delete hidden text after this Section has been edited for the Project.

PART 1 – GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.
- B. The Contractor's attention is specifically directed, but not limited, to the following documents for additional requirements:
 - The current version of the *Uniform General Conditions for Construction Contracts*, State of Texas, available on the web site of the Texas Facilities Commission.
 - The University of Houston's Supplemental General Conditions and Special Conditions for Construction.

DESCRIPTION OF WORK 1.2

Work Included: A.

- This Section shall furnish miscellaneous 120-volt control power circuits and control wiring as required for systems and equipment furnished by this and other Divisions. This control power and control wiring shall be furnished by this Section for all systems and equipment and where shown on the Drawings or approved Shop Drawings by the Division furnishing the system or equipment.
- In general, all starters and controllers for non 120-volt equipment and motors shall be furnished 2. with control power transformers, and control power circuits will not be required. Where control power transformers are not furnished, then 120-volt control power circuits shall be furnished by this Section.

EDIT TO SUIT PROJECT

- Miscellaneous Control Power and Control Wiring: Systems and devices requiring control power circuits and control wiring include, but are not limited to:
 - a. Automatic temperature control air compressors.
 - b. Automatic temperature control systems control power.

<Insert A/E Name> AE Project #: <Insert Project Number> UH Master: 08.2020

- c. Fireman's HVAC override panel with interconnection wiring to the Fire Alarm Control panel and interface with HVAC controls.
- d. Chiller control wiring for units with remote starters.
- e. Cooling tower vibration switches.
- f. Water treatment systems.
- g. Domestic water pump, surge tank and domestic water system controls.
- h. Sewage ejector and sump pump controls and alarms.
- i. Fire pump controls, [and battery chargers, jacket heaters] and alarms.
- j. Sprinkler alarms.
- k. Elevator and escalator controls.
- I. Contractor-furnished equipment controls.
- m. Owner-furnished equipment.
- n. Landscape sprinkler systems.
- o. Lighting and power control relays.
- p. Emergency generator/automatic transfer switch controls, battery chargers and jacket water heaters.
- q. Fuel oil system controls, monitoring and alarms.
- r. Remote annunciator, alarm panels, alarms and signaling devices/systems.
- s. Start/Stop stations where required for remote motor controllers.
- t. Additional control power, control wiring and safety devices as shown, specified, or required.

1.3 **QUALITY ASSURANCE**

- A. Manufacturers: Provide products complying with these specifications and produced by one of the following:
 - Relays:
 - a. Automatic Switch Company.
 - b. Russ Electric, Inc.
 - c. Square D Company.
 - d. Or equivalent with prior written approval by Engineer.

PART 2 - PRODUCTS

2.1 WIRING AND RACEWAYS

- Line Voltage Control Wiring: This wiring shall be as specified in Section 26 0519 "Insulated A. Conductors, Cables, Wires and Terminations."
- Low Voltage Control Wiring: This wiring shall be as specified in Section 26 0519 "Insulated В. Conductors, Cables, Wires and Terminations," except that conductors shall consist of a multiconductor jacketed cable whenever possible.

<Insert A/E Name> AE Project #: <Insert Project Number> UH Master: 08.2020 <Insert Project Name> <Insert U of H Proj #>

<Insert Issue Name>
 <Insert Issue Date>

C. Raceways: Raceways for line voltage and low voltage control wiring shall be as specified in Sections 26 0535 "Electrical Raceways" and 26 0534 "Electrical Boxes."

PART 3 - EXECUTION

3.1 INSTALLATION OF MISCELLANEOUS ELECTRICAL CONTROLS AND CONTROL WIRING

A. General: Install miscellaneous electrical control devices as shown, in accordance with applicable portions of the NECA's "Standard of Installation", and recognized industry practices to ensure that products serve the intended functions.

B. Requirements:

- 1. Miscellaneous control power circuits shall be obtained from spare breakers in building normal power panels. Where emergency system control power is required, or control power circuit requirements are large or significantly greater than normal, notify the Engineer in writing of the requirements.
- All control devices which are part of the Life Safety System and for equipment and devices served with emergency power shall have their control power derived from an emergency source.
- 3. Control wiring shown on the Drawings or specified in other Division 26 sections is not an inclusive listing of all control wiring required on the project. All required control wiring, unless noted otherwise herein, shall be furnished and installed by the Electrical Contractor.
- 4. HVAC temperature control wiring is specified and provided under Divisions 23 and 25 and is included in the Work of this Division. The only HVAC temperature control wiring and work included in the Work of this Division is providing 120-volt control power circuits for temperature controls (see Miscellaneous Control Power hereinabove) and coordination of Fire Alarm and Fireman's HVAC Override Panel connections to the temperature control system.
- 5. Provide 3/4-inch conduit for in-wall installation to all thermostat control wiring, stubbing up above ceiling.
- C. Conductors: Connect electrical conductors to miscellaneous electrical control devices in accordance with equipment manufacturer's written instructions and wiring diagrams. Wherever possible, match conductors of the electrical connection for proper interface between the electrical supply and the installed equipment.
- D. Contactors and Relays: Install contactors and relays mounted in panelboards or individual enclosures as shown and be complete, including all control wiring and devices.
- E. Lighting Controls: Install lighting controls as shown. Time program settings shall be as directed by the [Engineer] [Architect].
- F. Line and Low Voltage Control Wiring: Line and low voltage control wiring shall be installed in a suitable raceway.
- G. Connections: Refer to Section 26 2717 "Equipment Wiring" for connections to equipment.
- H. Number Code/Color Code: Number/color code all control power and control power conductors appropriately for future identification and servicing. Refer to Section 26 0533 "Identification for Electrical Systems" for additional requirements.

END OF SECTION 26 2718

<Insert A/E Name> Miscellaneous Electrical Controls and Control Wiring 26 2718 - 3
AE Project #: <Insert Project Number> UH Master: 08.2020