

## SECTION 08 31 13 - ACCESS DOORS AND FRAMES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:

- 1. Access doors and frames for walls and ceilings.

- B. Related Requirements:

- 1. Section 07 72 00 "Roof Accessories" for roof hatches.
- 2. Section 23 31 14 "Air Duct Accessories" for heating and air-conditioning duct access doors.

#### 1.3 ALLOWANCES

- A. Access doors and frames are part of an access door and frame allowance.

#### 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.

- 1. Include construction details[, **fire ratings**,] materials, individual components and profiles, and finishes.

- B. Shop Drawings:

- 1. Include plans, elevations, sections, details, and attachments to other work.
- 2. Detail fabrication and installation of access doors and frames for each type of substrate.

- C. Samples: For each door face material, at least 3 by 5 inches in size, in specified finish.

- D. Product Schedule: Provide complete access door and frame schedule, including types, locations, sizes, latching or locking provisions, and other data pertinent to installation.

## PART 2 - PRODUCTS

### 2.1 PERFORMANCE REQUIREMENTS

- A. Fire-Rated Access Doors and Frames: Units complying with NFPA 80 that are identical to access door and frame assemblies tested for fire-test-response characteristics according to the following test method and that are listed and labeled by UL or another testing and inspecting agency acceptable to authorities having jurisdiction:
1. NFPA 252 or UL 10B for fire-rated access door assemblies installed vertically.
  2. NFPA 288 for fire-rated access door assemblies installed horizontally.

### 2.2 ACCESS DOORS AND FRAMES FOR WALLS AND CEILINGS

- A. **Basis-of-Design Product:** Subject to compliance with requirements, provide product indicated or comparable product by one of the following:
1. [Acudor Products, Inc.](#)
  2. [Karp Associates, Inc.](#)
  3. [Milcor Inc.](#)
  4. <Substitutions: See Section 01 25 00 - Substitution Procedures.
- B. Source Limitations: Obtain each type of access door and frame from single source from single manufacturer.
- C. Flush Access Doors with Exposed Flanges :
1. Basis-of-Design Product: Acudor Products, Inc., model UF 5000 .
  2. Assembly Description: Fabricate door to fit flush to frame. Provide manufacturer's standard-width exposed flange, proportional to door size.
  3. Locations: Wall and ceiling .
  4. Door Size: **<Insert as shown on drawings door size>**.
  5. Uncoated Steel Sheet for Door: **[Nominal 0.060 inch, 16 gage] <Insert thickness>**.
    - a. Finish: **[Factory prime] [Factory finish]**.
  6. Metallic-Coated Steel Sheet for Door: **[Nominal 0.064 inch, 16 gage] <Insert thickness>**.
    - a. Finish: **[Factory prime] [Factory finish]**.
  7. Stainless-Steel Sheet for Door: **[Nominal 0.062 inch, @16 gage] <Insert thickness>**.
    - a. Finish: **[No. 4] [No. 2b]**.
  8. Frame Material: **[Same material, thickness, and finish as door] <Insert material, thickness, finish>**.
  9. Hinges: **[Manufacturer's standard] <Insert hinge type>**.
  10. Hardware: **[Latch] [Lock]**.

D. Exterior Flush Access Doors :

1. Basis-of-Design Product: Acudor Products, Inc., model UF 5500.
2. Assembly Description: Fabricate door to be weatherproof and fit flush to frame. Provide manufacturer's standard 2-inch- thick fiberglass insulation and extruded door gaskets. Provide manufacturer's standard-width frame for surface mounting, proportional to door size.
3. Locations: Wall .
4. Door Size: as shown on drawings. .
5. Metallic-Coated Steel Sheet for Door: Nominal 0.064 inch, 16 gage .
  - a. Finish: Factory prime .
6. Frame Material: Same material, thickness, and finish as door .
7. Hinges: Manufacturer's standard .
8. Hardware: Lock.

E. Fire-Rated, Flush Access Doors with Exposed Flanges :

1. Basis-of-Design Product: Acudor Products, Inc., model FW 5050.
2. Assembly Description: Fabricate door to fit flush to frame, with a core of mineral-fiber insulation enclosed in sheet metal . Provide self-latching door with automatic closer and interior latch release. Provide manufacturer's standard-width exposed flange, proportional to door size.
3. Locations: Wall and ceiling .
4. Fire-Resistance Rating: Not less than that of adjacent construction .
5. Temperature-Rise Rating: 250 deg F at the end of 30 minutes.
6. Metallic-Coated Steel Sheet for Door: [**Nominal 0.040 inch, 20 gage**] <Insert thickness>.
  - a. Finish: [**Factory prime**] [**Factory finish**].
7. Frame Material: Same material, thickness, and finish as door .
8. Hinges: Manufacturer's standard .
9. Hardware: Latch .

F. Hardware:

1. Latch: Cam latch operated by screwdriver .
2. Lock: Cylinder <Insert lock>.

## 2.3 MATERIALS

A. Steel Plates, Shapes, and Bars: ASTM A 36/A 36M.

B. Rolled-Steel Floor Plate: ASTM A 786/A 786M, rolled from plate complying with ASTM A 36/A 36M or ASTM A 283/A 283M, Grade C or D.

- C. Steel Sheet: Uncoated or electrolytic zinc coated, ASTM A 879/A 879M, with cold-rolled steel sheet substrate complying with ASTM A 1008/A 1008M, Commercial Steel (CS), exposed.
- D. Metallic-Coated Steel Sheet: ASTM A 653/A 653M, Commercial Steel (CS), Type B; with minimum G60 or A60 metallic coating.
- E. Rolled-Stainless-Steel Floor Plate: ASTM A 793, manufacturer's standard finish.
- F. Stainless-Steel Sheet, Strip, Plate, and Flat Bars: ASTM A 666, [Type 304] [Type 316]. Remove tool and die marks and stretch lines or blend into finish.
- G. Aluminum Extrusions: ASTM B 221, Alloy 6063-T6.
- H. Aluminum-Alloy Rolled Tread Plate: ASTM B 632/B 632M, Alloy 6061-T6.
- I. Aluminum Sheet: ASTM B 209, alloy and temper recommended by aluminum producer and finisher for type of use and finish indicated, and with not less than strength and durability properties of Alloy 5005-H15; with minimum sheet thickness according to ANSI H35.2.
- J. Frame Anchors: Same type as door face.
- K. Inserts, Bolts, and Anchor Fasteners: Hot-dip galvanized steel according to ASTM A 153/A 153M or ASTM F 2329.

## 2.4 FABRICATION

- A. General: Provide access door and frame assemblies manufactured as integral units ready for installation.
- B. Metal Surfaces: For metal surfaces exposed to view in the completed Work, provide materials with smooth, flat surfaces without blemishes. Do not use materials with exposed pitting, seam marks, roller marks, rolled trade names, or roughness.
- C. Doors and Frames: Grind exposed welds smooth and flush with adjacent surfaces. Furnish attachment devices and fasteners of type required to secure access doors to types of supports indicated.
  - 1. Provide mounting holes in frames for attachment of units to metal or wood framing.
  - 2. Provide mounting holes in frame for attachment of masonry anchors.
- D. Latching Mechanisms: Furnish number required to hold doors in flush, smooth plane when closed.
  - 1. For cylinder locks, furnish two keys per lock and key all locks alike.
  - 2. For recessed panel doors, provide access sleeves for each locking device. Furnish plastic grommets and install in holes cut through finish.

## 2.5 FINISHES

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
- C. Appearance of Finished Work: Noticeable variations in same piece are not acceptable. Variations in appearance of adjoining components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.
- D. Steel and Metallic-Coated-Steel Finishes:
  - 1. Factory Prime: Apply manufacturer's standard, fast-curing, lead- and chromate-free, universal primer immediately after surface preparation and pretreatment.
  - 2. Factory Finish: Immediately after cleaning and pretreating, apply manufacturer's standard two-coat, baked-on finish consisting of prime coat and thermosetting topcoat, with a minimum dry-film thickness of 1 mil for topcoat.
- E. Stainless-Steel Finishes:
  - 1. Surface Preparation: Remove tool and die marks and stretch lines, or blend into finish.
  - 2. Polished Finishes: Grind and polish surfaces to produce uniform finish, free of cross scratches.
    - a. Run grain of directional finishes with long dimension of each piece.
    - b. When polishing is completed, passivate and rinse surfaces. Remove embedded foreign matter and leave surfaces chemically clean.
    - c. Directional Satin Finish: No. 4.
  - 3. Bright, Cold-Rolled, Unpolished Finish: No. 2B.
- F. Aluminum Finishes:
  - 1. Mill finish.
  - 2. Clear Anodic Finish: AAMA 611, [**AA-M12C22A41, Class I, 0.018 mm**] [**AA-M12C22A31, Class II, 0.010 mm**] or thicker.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Comply with manufacturer's written instructions for installing access doors and frames.
- B. Install doors flush with adjacent finish surfaces or recessed to receive finish material.

3.3 ADJUSTING

- A. Adjust doors and hardware, after installation, for proper operation.
- B. Remove and replace doors and frames that are warped, bowed, or otherwise damaged.

END OF SECTION 08 31 13