

EMERGENCY OUTAGE NOTIFICATION

Building(s) Impacted and Date/Time

Building Name:	Lamar Fleming, Jr.	Building #:	564
Start Date:	Wednesday, 11/9/2022	End Date:	TBD
Start Time:	1:00 p.m.	End Time:	TBD

Purpose and Impact

PURPOSE: Air handler unit OAHU 1-15 is out of service due to a defective fan shaft.

IMPACT: The first floor perimeter hallways will experience increased temperatures and humidity.

Impacted Service

<input type="checkbox"/> Electric	<input type="checkbox"/> Gas	<input type="checkbox"/> Domestic Cold Water	<input type="checkbox"/> Elevators & Accessibility
<input type="checkbox"/> DI Water	<input type="checkbox"/> Construction	<input type="checkbox"/> Domestic Hot Water	<input checked="" type="checkbox"/> Air Handling Unit
<input type="checkbox"/> Steam	<input type="checkbox"/> Vacuum	<input type="checkbox"/> Chilled Water	<input type="checkbox"/> OTHER:

Primary Contact Information

Primary Contact: Jesus Aguirre

Secondary Contact: Joseph Carter

Please contact the FIXIT Call Center at 713-743-4948 or fixit@uh.edu to reach the primary contact.

Review and Approval Process (FBOC OFFICE USE ONLY)

Requested by: Joseph Carter
 Bldg Coordinator: M. Mahanay / E. Benavidez
 Fire Marshal: Marcus Hicks
 FS Director: Jose Perez
 FS AVP: Michael Oestereicher
 Issued by: Canon Wineriter

Request Date: 11/9/2022
 Email Date: 11/9/2022
 Email Date: 11/9/2022
 Email Date: 11/9/2022
 Approval Date: 11/9/2022
 Issue Date: 11/9/2022

Work Order#
Project #